




CRESTED BUTTE FIRE PROTECTION DISTRICT

306 MAROON AVENUE
 P.O. Box 1009
 CRESTED BUTTE, COLORADO 81224
 (970) 349-5333 FAX: (970) 349-3420

Gas Meter Location Agreement

Date _____ Subdivision _____
 Project Name _____ Contractor _____
 Location _____ Phone _____
 Owner _____ Plumber _____
 Address _____ Phone _____
 Phone _____ Fire Inspector _____
 CB Mt. CB County Map of Gas Meter Location (Indicate North on map)



CRESTED BUTTE FIRE PROTECTION DISTRICT REQUIREMENTS FOR THE LOCATION OF GAS METERS AND THEIR APPURTENANCES. GAS METERS, PRESSURE RELIEF VALVES, AND SERVICE LINES SHALL BE INSTALLED,
 -ON THE GABLE END OF THE BUILDING
 -3 FEET FROM ANY OPENING OR IGNITION SOURCE
 -3-5 FEET OFF FROM THE GROUND & PERMANENTLY ATTACHED TO THE STRUCTURE
 -NO EXPOSED, HORIZONTAL GAS LINES
 -IN ACCORDANCE WITH ALL APPLICABLE CODES AND MANUFACTURES DESIGN SPECIFICATIONS

***I am solely responsible and understand/agree to the location and installation of the gas meter and its appurtenances.**

SIGNATURES:

***CONTRACTOR/OWNER/DATE GAS COMPANY REPRESENTATIVE/DATE FIRE INSPECTOR/DATE BUILDING OFFICIAL/DATE**
 X _____ X _____ X _____ X _____

WHITE - CBFPD YELLOW - Gas Co. PINK - Responsible Party GOLD - Building Official